



## Salve Regina University

### Procurement and Installation of Lighting in the Young Ballroom

October 11, 2024

#### Response to Questions

1. Q: Are all new specified light fixtures and new lighting controls to be provided by EC or SRU?  
R: All new light fixtures and controls are to be provided by the Electrical Contractor.
2. Q: Are the existing light fixtures to remain or to be removed?  
R: Existing light fixtures are to remain.
3. Q: If the existing light fixtures are to remain, are they required to be connected to the new lighting control system?  
R: Existing light fixtures are to remain on existing controls – not tied into new control system.
4. Q: Where is electrical feed for new ceiling fixtures expected to come from?  
R: Feed for new ballroom ceiling fixtures is expected to drop down from the second floor corridor above the ballroom from the panel located in the adjacent second floor stairwell.
5. Q: Is the EC responsible for painting, patching, and possible carpentry work costs associated with concealing the new lighting cables within the existing ceilings and walls?  
R: EC is not responsible for patching, painting and carpentry associated with concealing new lighting cables, however close coordination with SRU is expected in order to preserve and minimize disruption to existing conditions.

End of Response to Questions