



## Salve Regina University

Audio Visual and Network Cabling Design-Build, New Student Center “Papitto” Pavilion

September 8, 2025

### Response to Questions

1. *Q: What type of lighting are you looking for?*

R: The RFQ provides a general description of the necessary lighting component to be provided. It is expected that as part of the pre-construction phase, specific lighting fixtures will be proposed, priced and selected.

2. *Q: Would we be able to submit a proposal that does not include the lighting portion?*

R: Please review the Cost Proposal description in the “Submission Requirements” section of the RFP for the requested pricing information.

3. *Q: What is the size of the area to be lit?*

R: See the attached floor plans in Appendix #2 for dimensions of the room. The “stage” area will be no larger than 37’ wide X 21’ deep, actual dimension to be determined during pre-construction.

4. *Q: how do you wish to control the lighting?*

R: The lighting provided through this RFP should be controlled through the Control & Switching platform.

5. *Q: what type of power is there?*

R: All other lighting in the space is specified at 120V. There is a lighting relay panel which has three spare zones. Each zone is rated 20A, 120V, 1920W.

6. *Q: What is the fixture throw distance? the stage size? ceiling height?*

R: See response to Q3.

7. *Q: The displays proposed in the RFP will not satisfy the request for an optimum viewing experience?*

R: Please see addendum #1 dated 09/08/25. Final design of the space and components will take place during the AV pre-construction phase.

**\*\*End of Response to Questions\*\***